



Components Trading Marketing GmbH
Bürknersfelder Strasse 7 b
13053 Berlin

Telefax : + 49 30 – 98 69 60 63
E-mail : info@CTM-Berlin.de
Internet : www.CTM-Berlin.de

Operating instruction for valve-regulated lead-acid batteries

Type OGiV

Nominal data:

● Nominal voltage U_N	2,0 V x number of cells (12V/6V/2V)
● Nominal capacity C_{20}	20h discharge
● Nominal temperature T_N	20° C
● Factors of reduction	for ventilation (draft DIN/VDE 0510 part 1) factor $f_1 = 0,5$ $f_2 = 0,5$
● Nominal discharge current $I_N = I_{20}$	$C_N/20h$

Battery Type:	
Assembly by:	date:
Commissioned by:	date:
Security signs attached by:	date:
Yuasa order no.:	

	● Observe these instructions and keep them located nearby the battery for future reference! Work on the battery should only be carried out by qualified personnel!
	● Do not smoke! Do not use any naked flame or other sources of ignition. Explosion and fire hazards are present!
	● While working on batteries wear protective eye-glasses and clothing! Observe the accident prevention rules as well as DIN VDE 0510, VDE 0105 part 1!
	● Any acid splashes on the skin or in the eyes must be flushed with plenty of water immediately. Then seek medical assistance. Spillages on clothing should be rinsed out with water!
	● Explosion and fire hazard, avoid short circuits! Caution! Metal parts of the battery are always alive, therefore do not place items or tools on the battery!
	● Electrolyte is strongly corrosive and acidic. In normal working conditions the contact with electrolyte is nearly impossible; electrolyte may leak from the vent valves in case of over charging the battery or in case of mechanical damage to the container. In case of any contact with electrolyte please flush with water abundantly and get in touch with a physician.
	● Batteries/cells are heavy! Ensure adequate mounting security and always use suitable handling equipment for transportation!
Non-compliance with operation instructions, repairs made with other than original parts, or repairs made without authorization (e.g. opening of valves) render the warranty void.	
	Disposal of Batteries Batteries marked with the recycling symbol should be processed via a recognised recycling agency. By agreement, they might be returned to the manufacturer. Batteries must not be mixed with domestic or industrial waste.

Valve-regulated lead acid batteries consist of cells which do not require water topping during the operation.

M 5	M 6	M 8	M 10
2 – 3 Nm	4 – 5,5 Nm	5 – 6 Nm	14 – 22 Nm

1. Start up

Check all cells/blocks for mechanical damage, correct polarity and firmly seated connectors. The following torques apply for screw connectors:

Connect the battery with the correct polarity to the charger. The charger should not be switched on during this process, the load should not be connected (pos. pole to pos. terminal). Switch on charger and start charging following instruction no. 2.2.

2. Operation

For the installation and operation of the batteries, EN 50 272-2 is mandatory. Battery installation should be made such

that temperature difference between individual units does not exceed 3 degrees Celsius/Kelvin.

2.1 Discharge

Discharge must not be continued beyond the level specified for the specific discharge current. Deeper discharges must not occur unless specifically agreed with the manufacturer. Recharge immediately following complete or partial discharge.

2.2 Charging

Applicable are all charging procedures with their limit values according to DIN 41773 (IU-characteristic). According to the charging equipment specification and characteristics, alternating currents ($< 0,1C(A)$) flow through the battery superimposing into the direct current during charging operation. These alternating current and the reaction from the loads lead to an additional temperature increase of the battery, and strain the electrodes with

possible damages (see 2.5). Depending on the installation, charging (acc. to EN 50 272-2, draft) may be carried out in the following operations.

a) Standby Parallel Operation and Buffer Operation

Here the load, direct current source and battery are continuously in parallel. Thereby the charging voltage is the operation-voltage and at the same time the battery-installation voltage. With the standby parallel operation, the direct current source is at any time capable of supplying the maximum load current and the battery charging current. The battery only supplies current when the direct current source fails. The charging voltage should be set at $2,275V \pm 0,005V$ (at 20°C) x number of cells in series measured at the terminals of the battery. With buffer operation, the direct current source is not able to supply the maximum load-current at all times. The load-current intermittently exceeds the nominal current of the direct source. During this period the battery supplies power. The battery is not fully charged at all times but the float-charge voltage of $2,275 V/cell \pm 0,005 V$ (at 20°C) x number of cells in series provides a reasonable recharge duration under normal conditions. Dependent on load and number of cells in series, it is recommended to consult the battery manufacturer in any doubtful case.

b) Switchmode-Operation

When charging, the battery is separated from the load. To reduce the charging time, a three phase boost charge mode can be applied by charging the battery at 2,45 – 2,5 V/cell until the charging current drops to 0,07 C(A) (trip point for the first phase of charging t_1). The duration of charging of the first phase is measured by a timer so that the second phase should be half of the first phase ($t_2 = 0,5 t_1$) when the batteries are kept on charge at 2,45 – 2,5 V/cell. After the total charging of $t=t_1+0,5t_1$ has elapsed, the charger reduces the voltage to a normal float-charge level of 2,275 V/cell ($\pm 0,005V$) at 20° C.

c) Battery operation (charge/discharge operation)

The load is only supplied by the battery. The charging process depends on the application and must be carried out in accordance with the recommendations of the battery manufacturer.

2.3 Maintaining the full charge (float charge)

Devices complying with the stipulations under DIN 41773 must be used. They are to be set so that the average cell voltage is $2,275 V \pm 0,005V$.

2.4 Supplementary and Equalizing charge

To ensure maximum service life, a supplementary charge may be required prior to

installation on condition that the batteries have been in storage for more than 6 months or more, latest after 9 months age from the date of production and that the open circuit voltage is less than 2.1 Volts per cell. A supplementary charge should be applied in accordance with figures shown in the table:

Storage Period	Charge V/c at 20° C	Charge Time
less than 9 months	2,275 V/cell	more than 72 hours
up to 1 year	2,35 V/cell	48 – 144 hours
1 – 2 years	2,35 V/cell	72 – 144 hours

Batteries kept at normal float charge level within a string do not require any equalizing charge in case of partial replacement, in order to narrow the bandwidth of open-circuit voltages.

2.5 Alternating currents

On recharging up to 2.4 V/cell under operation modes 2.2 the actual value of the alternating current is for a very short time permitted to reach 0,1C(A) nominal capacity. In a fully charged state during float charge or standby parallel operation the actual value of the alternating current must not exceed 5 A/100 Ah nominal capacity.

2.6 Charging currents

During float charge or standby parallel-operation without recharging state the charging currents are not limited. The charging current should range between 10 A to 20 A/100 Ah nominal capacity.

2.7 Temperature

The nominal operation temperature range for lead-batteries is 10°C to 30°C (best 20°C ± 5 K). Higher temperatures will seriously reduce service life. All technical data are produced for a nominal temperature of 20°C. Lower temperatures reduce the available capacity. The absolute maximum temperature is 50°C and should not permanently exceed 40°C in service.

2.8 Temperature-related float charge voltage and boost charge

The float charge voltage of 2,275V/cell ± 0,005V/cell refers to a battery temperature of 20°C. Temperature compensated charging is required in order to avoid over-charge at high temperatures and under-charge at low temperatures. The recommended temperature compensation factor is -3m V/cell/°C for float charge operation. In order to avoid thermal runaway, it is mandatory to temperature-compensate the float-charge voltage for temperatures above 40°C.

The boost charge mode can be applied if a quick recharge is required on condition that the charging current does not exceed 0,25C(A) and constantly drops to 0,01C from where normal float charge voltage should be applied.

temperature [°C]	boost charging voltage [V/c]	maintenance charge voltage [V/c]
- 10	2,58	2,36
0	2,53	2,33
10	2,48	2,30
20	2,45	2,275
30	2,40	2,24
40	2,34	2,21

2.9 Electrolyte

The electrolyte is diluted sulphuric acid and is absorbed in glass-matt separator (CTL), GEL CTV.

3. Battery maintenance and control

Keep the battery clean and dry to avoid leakage currents.

Plastic parts of the battery, especially containers, must be cleaned with pure water without additives, any organic solvents are prohibited.

At least every 6 months measure and record:

- battery voltage
- voltage of several cells/blocks
- surface temperature of several cells/blocks
- battery-room temperature

If the difference of the average float-charge-voltage/cell is exceeding ± 0.1 V/cell within a string or if the surface temperature-difference between cells/blocks is exceeding 5 K, the service-agent should be contacted.

Annual measurement and recording:

- voltage of all cells/blocks
- surface temperature of all cells/blocks
- battery-room temperature
- insulation-resistance according to DIN 43539 part 1

Annual visual check:

- screw-connections, any screw connections without locking devices have to be checked for tightness
- battery installation and arrangement
- ventilation

4. Tests

Tests have to be carried out according to IEC 896-2, DIN 43539 part 1 and 100(draft) Special instructions like DIN VDE 0107 and DIN VDE 0108 have to be observed.

5. Faults

Call the service agents immediately in case of faults in the battery or the charging unit. The availability of the recorded data described in point 3, will be very helpful to find the cause of failure. A service-contract simplifies trouble-shooting.

6. Storage and taking out of operation

To store or decommission cells/batteries for a longer period of time, they should be fully charged and stored in a dry frost-free room. To avoid damage, batteries should be regularly subjected to supplementary charge cycles in accordance with 2.4..

7. Transport

VRLA batteries, which by no means show any kind of damage, are classified as non-dangerous goods for transportation via rail, lorry or air (according to GGVS, GGVE and IATA Regulations) if they are safeguarded during transportation against short-circuiting, tossing about, slipping or any damage. Batteries to be classified under aforementioned paragraph must mandatorily not display any traces of electrolyte on the exterior of the battery container.

As for VRLA batteries being damaged, assumed to be leaking of electrolyte and to be transported under warranty, or assumed not to be tight in any aspect anymore, they are to be handled in accordance with exception regulations of dangerous goods transportation rules concerned.

8. Technical data Capa (Cn) at different discharge times (Tn) until the final discharge							
voltage (V/C) at battery temperature 20C							
Typ	20h C ₂₀ (Ah) to 1.85V/Z	10h C ₁₀ (Ah) to 1.8V/Z	5h C ₅ (Ah) to 1.75V/Z	3h C ₃ (Ah) to 1.75V/Z	1h C ₁ (Ah) to 1.70V/Z	30Min. C ₁₀ (Ah) to 1.7V/Z	10Min. C ₁₀ (Ah) to 1.7V/Z
CTL AGM							
CTL 18-12	17,2	15,3	14,3	13,5	11	9,6	6,9
CTL 26-12	26	23,4	21,3	19,6	18,1	17,35	11,3
CTL 28-12	28	25,3	23	21,2	19,5	18,7	12,2
CTL 33-12	32	28,3	25	23	21,5	19,25	13,9
CTL 44-12	38,9	35,9	32,2	31	28,7	25,5	19
CTL 55-12	50,9	45,8	41,6	39,1	35,5	30,2	23,66
CTL 70-12	64,2	57,2	52,5	50,9	47,8	41,1	29,66
CTL 80-12	73,1	65,9	61,2	58	55,6	46,5	31,66
CTL 90-12	82,9	75,7	70	66,8	59,2	50,85	36
CTL 100-12	91,9	85,1	75,8	72,5	65	56	40,5
CTL 100-12	102	93,1	83,3	78,7	69,8	62,5	43,66
CTL 120-12	112	104	93	90	80,7	68,5	46,83
CTL 135-12	123	115	105	103	100	84	53,83
CTL 150-12	139	128	115	110	104	90	56,33
CTL 160-12	154	146	131	125	115	94,5	59,66
CTL 200-12	186	172	158	151	140	110,5	63
CTL 230-12	214	200	179	167	147	115	65,5
CTV GEL							
CTV 7,0-12	6,6	6,41	5,89	5,54	4,32	3,68	2,38
CTV 12-12	10,9	10,9	9,81	9,23	7,34	6,1	12,35
CTV 18-12	15,2	13,5	12,6	11,8	9,25	7,8	5,26
CTV 26-12	24,7	22,3	21,2	19,9	15,6	13,15	8,78
CTV 33-12	30,4	26,9	23,7	21,6	19,5	16,8	11,41
CTV 44-12	37	34,1	30,6	29,1	25	22,3	15,66
CTV 55-12	48,4	43,5	39,5	36,6	32,2	26,45	19,5
CTV 70-12	61	54,4	49,8	47,8	43,3	35,95	24,33
CTV 80-12	69,5	62,6	58,1	54,4	50,4	40,65	26
CTV 90-12	78,8	71,9	66,4	62,7	53,6	44,45	29,5
CTV 100-12	83,8	77,7	69,1	65,3	56,5	46	31,33
CTV 110-12	97	88,5	79	73,8	63,2	54,65	35,83
CTV 120-12	106	99	88,3	84,4	73,1	60	38,5
CTV 135-12	117	109	99	97	86,5	66,5	36,16
CTV 150-12	132	122	109	103	93,8	77	45
CTV 160-12	146	139	124	117	104	83	49
CTV 200-12	177	163	150	141	126	96,5	51,66
CTV 230-12	204	191	170	156	133	100,5	53,83